

# Japan Demand Response Market Overview

November 7, 2019

**Hideo Ishii, Ph.D.**

Professor

*Advanced Collaborative Research Organization  
for Smart Society (ACROSS)*

*& Research Institute*

*for Advanced Network Technology (RIANT)*

Waseda University

&

Energy Resource Aggregation Business Forum

&

Chief Director, ADR Japan



# OUTLINE

---

- **History of DR and VPP in Japan**
- **National Framework of DR / VPP**
- **Communication Architecture and Deployment of OpenADR**
- **Application to VRE Control**
- **Implementation Guide in Japan**
- **Application to upcoming the Balancing Market**

# History of DR/VPP in Japan

---

- 2011.3.11    **Great East Japan Earthquake, Fukushima Nuc.-Accident**  
→ Rolling Blackout in TEPCO Area,  
Nation-wide campaign for saving kWh
  
- 2012.6  
(METI)        **DR Initiative :**  
**“Smart House & Building Standardization and Business Study Committee”**
  - ✓ DR Use Cases
  - ✓ Communication Standards :  
ECHONET Lite (HAN),  
OpenADR(TSO-Aggregator)
  
- 2016.1  
(METI)        **“Energy Resource Aggregation Business Study Committee”**

# METI's Official Announcement

## @ 3rd Meeting of “Smart House & Building Standardization and Business Study Committee” (May 15, 2013)


### ✓ DR Technology and Standard

- Summarize **use cases** of demand response (DR) and prepare a **standard method** for automated DR between power utilities and aggregators **based on OpenADR**
- Establish **test facility at Waseda University**

### ✓ Specification and Policy

- Summarize “Specification for DR interface, Ver1.0” which covers OpenADR 2.0a and a part of 2.0b.
- In this framework, vendors are supposed to develop their soft or hard wares in compliance with the conformance rule determined by OpenADR Alliance (Spec. 2.0a and/or 2.0b).

# Standardization of Communication Interface for DR (2013- )



# History of DR/VPP in Japan

## ● DR/VPP Demonstration

TEPCO-BSP  
(2012 - 2013)

- 5 Aggregators
- Customers  
Factory, Stores,  
Office, Hotels
- Device  
Private Generator,  
Factory Machinery  
HVAC, Light,


METI-Incentive DR  
(2014 - 2015)

- 21 Aggregators  
36,700 Resources
- Customers, 2100  
Factory, Stores,  
Office, Hotels
- Device  
Private Generator,  
Factory Machinery  
HVAC, Light,  
Battery,  
Thermal storage

METI-VPP  
(2016- on going)

- 6AC + 35 RA  
31.5MW of resources
- Customers  
Factory, Stores,  
Office, Hotels
- Device  
Private Generator,  
Factory Machinery  
HVAC, Light,  
Battery, Pump  
Thermal storage,  
EV, Refrigerator  
Co-generation, FC

# Latest Demonstration of DR (VPP)




# Who is playing an aggregator? – From 2017 demonstration

- **6 AC groups + 35 RA + 31.5MW Resources**

| Aggregation Coordinator                 | Resource Aggregator                      | Resources   |
|---|--|---|
| Azbil<br>TEPCO EP, et al.               | Azbil                                    | BES, Thermal Storage, Generator, HVAC, etc.           |
| SB Energy, et. al                       | Loop + 9 RAs                             | BES, PV, HPWH   |
| Eneres, et al.                          | KDDI + 2 RAs                             | BES, Generator, HVAC, EVPS, etc.                      |
| Kansai EPCO, et al.                     | KYOCERA + Panasonic + SHARP + 10 RAs     | BES, HPWH, HVAC, EVPS, Refrigerator, water pump       |
| Global Eng., TEPCO HD, TEPCO PG, et al. | TEPCO EP + Osaki + SEKISUI Chem. + 5 RAs | BES, Generator, Light, HVAC, EVPS, etc.               |
| Lawson + Keio Univ.                     | Lawson                                   | Refrigerator, HVAC, Light, BES, PV, Heat Storage, etc |




# Architecture of FY2017 Demonstration




# Electric Power System Reform and Markets

## Road Map of EPSR

- Purpose
- ① Ensuring Stable power supply
  - ② Suppress electricity tariff
  - ③ Expansion of customer choice and business opportunity



# Category and required capacity for adjustment



# Adjustment Capacity Procurement

- **Generator I' : 958MW of DR (35 MUSD) by 4 utilities for 2017 almost same for 2018**
- **Communication system (VTN/VEN) based on OpenADR2.0b Requirement by TSOs**




|                         | Generator I-a | Gnerator I-b | Generator I'    |
|-------------------------|---------------|--------------|-----------------|
| On Line Control         | Mandate       | Mandate      | Not necessarily |
| Frequency Regulation FN | Mandate       | None         | None            |
| Response Time           | <5 min.       | <15 min.     | < 3 hours       |
| Duration                | 7 – 11 hours  | 7 – 16 hours | 2 – 4 hours     |
| Minimum Capacity        | 5 – 15 MW     | 5 – 29 MW    | > 1 MW          |
| DR (negawatt)           | Not allowed   | allowed      | allowed         |

# Revision of FIT by METI/ANRE (December, 2014)


## □ New Output Control Scheme

- Remote control function, All capacity
- <360hr/year, without compensation

## □ Demonstration PJ (Dec. 2015-Jan. 2016)



# Role of DR & RE dispatch center



# OpenADR Implementation Guide Documents

## Demand Response Interface Specification, Ver. 2.0

ディマンドレスポンス・インタフェース  
仕様書

第2.0版

2019年4月1日

エネルギー・リソース・アグリゲーション・ビジネス検討会

## OpenADR Device Implementation Note Ver. 1.1

OpenADR  
機器別実装ノート

第1.1版

2019年4月1日

Both available @  
[https://www.enecho.meti.go.jp/category/saving\\_and\\_new/  
advanced\\_systems/vpp\\_dr/download.html](https://www.enecho.meti.go.jp/category/saving_and_new/advanced_systems/vpp_dr/download.html)



# Categories and requirements in Japanese Balancing Market


|                | Primary (GF)        | Secondary-1 (LFC)   | Secondary-2 (EDC-H) | Tertiary (EDC-L)    | Tertiary (Slow Res.) |
|----------------|---------------------|---------------------|---------------------|---------------------|----------------------|
| Name*          | FCR                 | S-FRR               | FRR                 | RR                  | RR-FIT               |
| Order/Control  | —                   | Order/Control       | Order/Control       | Order/Control       | Order                |
| Comm. Line     | —                   | Private NW, etc.    | Private NW, etc.    | Private NW, etc.    | Dispatch system      |
| Monitor        | on line             | on line             | on line             | on line             | on line              |
| Response       | < 10 sec            | < 5 min             | < 5 min             | < 15 min            | < 45 min             |
| Duration       | > 5 min             | > 30 min            | > 30 min            | 3 hr                | 3 hr                 |
| Max. bidding   | As much as possible | As much as possible | As much as possible | As much as possible | As much as possible  |
| Min. bidding   | 5MW                 | 5MW                 | 5MW                 | 5MW                 | 1MW                  |
| Order period   | autonomous          | 0.5~10sec           | 1~a few min         | 1~a few min         | 30 min               |
| Monitor period | 1~a few sec         | 1~5 sec             | 1~5 sec             | 1~5 sec             | TBD                  |
| Bidding unit   | 1kW                 | 1kW                 | 1kW                 | 1kW                 | 1kW                  |
| Category       | up / down           | up / down           | up / down           | up / down           | up / down            |



# Target Point

## Target Point :

- ✓ Estimated demand in every thirty minutes during the DR-period based on the real demand before dispatch.
- ✓ Values of the Target Points during the DR period as well as those during the response period should be determined and reported to TSO by the ACs
- ✓ Target Points will be used as the “base lines” for the settlement



תודה

Dankie Gracias

Спасибо

شكراً

Merci Takk

Köszönjük

Terima kasih

Grazie

Dziękujemy

Dėkojame

Ďakujeme

Vielen Dank

Paldies

Kiitos

Täname teid

谢谢

**Thank You**

Tak

感謝您

Obrigado

Teşekkür Ederiz

Σας Ευχαριστούμ

감사합니다

ඔබටත

Bedankt

Děkujeme vám

ありがとうございます

Tack

[hideishii@aoni.waseda.jp](mailto:hideishii@aoni.waseda.jp)

